RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 11/11/2026

Area: OHP

Equipment	Job
cbms on co-11a	conveyor motor removed for matching with spare one and fixed back in position.
co-9a,12a	motor side ppm is done, greasing is done at both ends for 2 motors.
tbs-4 on co-22	PCRD cable loops formed and got stuck between drum and slip ring, got crushed. Joint done by DNW. Angles welded back in place to prevent cable entry between drum and slip ring. cable winding is done properly.