



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/08/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO 6A(B)	olr acted	reset	19:20:00	19:25:00	
2	OHP	RSCO 6A(c)	olr acted due to jamming	reset	19:35:00	19:45:00	
3	OHP	VS 5A	olr acted	reset	21:10:00	21:15:00	
4	OHP	tbs on co 22	R luff not working,add on contactor to mpcb not connected properly	fixed properly	15:40:00	15:50:00	
5	OHP	co 26	olr acted	reset	16:15:00	16:30:00	
6	OHP	wobr on co 25	LT not working,M4 mpcb tripped due to jamming	made it on,informed operation	19:45:00	20:00:00	
7	CHP	co 29	olr	reset	21:05:00	21:10:00	
8	CHP	CC 51	mpd acted	reset	19:00:00	19:05:00	
9	CHP	CC 52	mpd tripped	reset	20:40:00	20:45:00	
10	CHP	CC 54	motor tripped in olr	reset	16:20:00	16:25:00	5 times
11	CHP	CC 131	olr acted	reset	16:40:00	16:45:00	2 times