



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 08/09/2026

Area: CHP

| Equipment                | Job                                                              |
|--------------------------|------------------------------------------------------------------|
| SCR 10                   | Instrumentation sensors maintenance was done                     |
| SCR 6                    | Running inspection defect rectified                              |
| CC 202                   | New BRS unit installed,wiring pending                            |
| CM 18                    | PLC panel painting done                                          |
| S 1                      | PCRD motor power cable lug crimped,resistance contactor replaced |
| Transfer car             | Power cable joints inspected and taping done                     |
| CM 27                    | Rooms cleaning done                                              |
| Transfer car,CC 38,SCR 6 | PPM was done                                                     |
| CC 51,51A                | PPM was done                                                     |