



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/05/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO 29	PCRD O/T ACTED	RELEASED	22:30:00	22:40:00	
2	OHP	CO 26	OLR ACTED	RESET	05:20:00	05:30:00	
3	OHP	CO 62	MPCB TRIP	RESET	00:20:00	00:30:00	
4	CHP	SCR 1 ON CC 31 SLEW	DRIVE TRIP	RESET	05:35:00	05:45:00	
5	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	02:15:00	03:10:00	3 TIMES
6	CHP	CC 52	FEEDING CONV OLR ACTED	RESET	23:25:00	05:05:00	5 TIMES
7	CHP	CC 51	OLR ACTED	RESET	02:40:00	03:00:00	2 TIMES
8	WT	OT 4	D2 TRIP	RESET	05:05:00	05:10:00	