



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/07/2026

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	TRIPPED ON OLR	RESET DONE	01:00:00	01:05:00	
2	CHP	CC 58	TRIPPED ON OLR	RESET DONE	03:55:00	04:20:00	
3	CHP	SCR 3 ON CC37	SLEW NOT TAKINGPLACE/OIL LEVEL LOW	INFORM TO MECH.	23:30:00	23:50:00	PIPE LEAKAGE
4	CHP	SCR 9 ON CC213	BC NOT RUNNING//SIGNAL MISSING	LT DONE THEN OK	23:35:00	23:45:00	
5	CHP	SCR 2 ON CC33	BC NOT RUNNING/SLEW 30DEGREE LIMIT ACTED	RELEASED	00:20:00	00:40:00	
6	CHP	CC 201	TRIPPED ON OLR	RESET DONE	23:25:00	23:30:00	
7	CHP	CC 131	TRIPPED ON OLR	RESET DONE	05:35:00	05:40:00	
8	WT	OT 5	F/R NOT TAKING PLACE/TOP CLAMP LS 7 ACTED	BYPASSED IN SCADA	03:40:00	03:45:00	