



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/06/2026

Incharge(s): P Venkat Kiran,P Venkat Kiran

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 6a	no drives running/acb tripped	acb made on	08:10:00	08:20:00	
2	OHP	CR 2A	TRIPPED ON VIBRATION	RESET AFTER 10 MIN.	12:10:00	12:30:00	
3	CHP	SCR 3 ON CC37	LT NOT TAKING PLACE/M3 OLR ACTED	LT M3 RESET DONE	07:25:00	07:35:00	
4	CHP	SCR 10 ON CC105	LT NOT TAKING PLACE/PCRD TENSION ACTED	RELEASED	12:35:00	12:45:00	
5	CHP	CC 58	TRIPPED ON SP FAULT	RESET DONE	07:00:00	07:15:00	
6	WT	OT 5	F/R NOT TAKING PLACE/LS 4 LIMIT ACTED	LIMIT BYPASSED IN SYSTEM	12:20:00	12:30:00	