



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 04/06/2026

Incharge(s): Nagendra Midde

Shift: A

| Sl No | Area | Equipment            | Problem                | Action                 | From     | To       | Remarks |
|-------|------|----------------------|------------------------|------------------------|----------|----------|---------|
| 1     | CHP  | CC 51                | FEEDING CONV OLR ACTED | RESET                  | 13:20:00 | 13:25:00 |         |
| 2     | CHP  | SCR 4 ON<br>CC 32 LT | M9 TRIPPED             | RESET                  | 06:55:00 | 07:05:00 |         |
| 3     | CHP  | SCR 7 ON<br>CC 39    | LT END LIMIT           | PROPERLY FIXED THEN OK | 08:20:00 | 08:40:00 |         |