



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/08/2026

Incharge(s): Nagendra Midde,K SANKARA RAO

Shift: B

| Sl No | Area | Equipment        | Problem                                             | Action                                                 | From     | To       | Remarks |
|-------|------|------------------|-----------------------------------------------------|--------------------------------------------------------|----------|----------|---------|
| 1     | OHP  | BRC on CO 32 B/W | OIL level Low                                       | Informed to mech                                       | 15:20:00 | 15:35:00 |         |
| 2     | OHP  | CO 26            | OLR acted                                           | Reset                                                  | 18:55:00 | 19:05:00 |         |
| 3     | OHP  | CO 11A           | Motor Fan Finns got damaged and Fan cover Fell down | Fan cover Properly placed and Pedestal fan is provided | 19:30:00 | 20:00:00 |         |
| 4     | CHP  | CC 130           | Motor coupled                                       | Trail Run taken                                        | 18:00:00 | 20:15:00 |         |
| 5     | CHP  | Scr 7 On CC 40   | B/C Olr acted                                       | Reset                                                  | 20:30:00 | 20:45:00 |         |
| 6     | CHP  | CC 51            | Feeding conv Olr acted                              | Reset                                                  | 17:35:00 | 17:40:00 |         |
| 7     | IOSA | OC 27 A          | Healthy Stop Due to PC acting momentarily           | Bypassed                                               | 20:20:00 | 21:00:00 |         |
| 8     | IOSA | L and T WBR B/W  | Suction Valve LS1 acted                             | Released                                               | 17:00:00 | 17:30:00 |         |
| 9     | IOSA | L and T WBR LT   | Rev End limit Acted                                 | Released                                               | 17:00:00 | 17:15:00 |         |