



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/09/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on co 21	LT not working,M1mpcb tripped	reset	19:50:00	20:00:00	
2	OHP	VF 15A	olr acted	reset	21:10:00	21:20:00	
3	OHP	rsco2A	olr acted	reset	21:20:00	21:30:00	
4	OHP	RSCo 6A	olr acted,jamming	reset	21:00:00	21:10:00	3 times
5	OHP	wobr on co 25	PCRD cable joint open and pulled	pending	21:45:00	22:00:00	
6	OHP	BRc on Co 30	LT not working,s/s in local	kept in remote	21:40:00	21:50:00	
7	CHP	CC 51 A	mpd tripped	reset	19:20:00	19:30:00	
8	WT	OP1	not moving,emergency acted	emergency released	21:05:00	21:20:00	not electrical delay