



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/09/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR on CO 25	OLD HT joint Opened	Joint done b DNW	22:00:00	02:00:00	
2	OHP	BRC on CO 28 B/W 1	OLR acted	Reset	00:20:00	00:40:00	
3	OHP	TBS on CO 5a LT	M1 , M4 trip due to break stuck	Reset and Informed to Mech	01:45:00	02:00:00	
4	OHP	BRC on CO 30 B/C	OLR acted	Reset	02:40:00	03:00:00	
5	OHP	TBS on co 19 Left Luff	OLR acted	Reset	04:30:00	04:45:00	
6	OHP	CO 26	Olr acted	Reset	02:05:00	04:45:00	3 times
7	OHP	RSCO 6a	OLR acted	Reset	02:45:00	05:55:00	3 times
8	OHP	CR 3a	Hydraulic Pump MPCB Trip	Made it on	04:30:00	05:10:00	
9	CHP	SCR 3 on CC 37	B/C Olr acted	Reset	00:30:00	04:45:00	2 times
10	CHP	SCR 6 on CC 38 Slew	Limits Common High Mcb Tripped	Made it on	01:20:00	01:40:00	
11	CHP	SCR 2 on CC 33 B/C	OLR acted	Reset	03:15:00	03:30:00	
12	CHP	SCR 9 on CC 104	ACB trip	Made it on	04:00:00	04:20:00	
13	CHP	CC 112 DE	C/S bypassed	Due to Rain	02:00:00	02:10:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/09/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 28 T/T C/S	Probe Cable Problem	bypassed and Replacement under Progress	04:00:00	06:00:00	
15	WT	CO 3	OLR acted	Reset	22:10:00	00:40:00	2 times