वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 05/11/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS 2a	OLR acted	Reset	01:20:00	01:25:00	
2	OHP	CO 25	OLR acted	Reset	22:00:00	04:35:00	3 times
3	OHP	WBR on CO 26	Luff MPCB trip	Reset	23:15:00	01:40:00	2 times