



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/06/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 30	CHUTE SENSOR ACTING FREQUENTLY	BYPASSED	23:25:00	23:55:00	
2	OHP	BRC ON CO 30 CT	EMERGENCY STOP ACTED	RELEASED	02:15:00	02:30:00	
3	OHP	WBR ON CO 29	LUFF OLR ACTED	RESET	02:45:00	03:00:00	
4	OHP	CO 26	OLR ACTED	RESET	05:35:00	05:45:00	
5	OHP	CO 25	OLR ACTED	RESET	23:20:00	23:30:00	
6	WT	AF6	DRIVE TRIPPING FREQUENTLY ON OVER CURRENT	PAN MOVEMENT IS NOT UNIFORM INFORMED TO OPRN	00:30:00	01:00:00	