



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/05/2026

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	OLR ACTED	RESET DONE	01:55:00 04:25:00	02:05:00 04:35:00	
2	OHP	BRC ON CO 34	BW-1 NOT RUNNING ... STUCK	INFORMED MECH	04:35:00	04:45:00	
3	CHP	CC-125	TRIPPED ON OLR	RESET DONE	02:20:00	02:30:00	