



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/06/2026

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	Reported tripped	OLR acted.Reset done	17:35:00	17:45:00	
2	OHP	CO-29	Reported tripped	OLR acted.Reset done	20:15:00	20:25:00	
3	CHP	CC-38 SCR-5	LT not taking place	M5 motor tripped.Reset done	16:35:00	16:50:00	
4	CHP	Cc-40 SCR-7	B/C not running	ACB tripped.Made on	20:00:00	20:15:00	
5	CHP	CC-51	MPD tripped	Reset done	16:15:00	16:20:00	
6	CHP	Cc-54	MPD tripped	Reset done	19:50:00	19:55:00	
7	WT	OP-2	Reported not moving	Brake binding found.	14:40:00	15:00:00	Informed to operation