



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/08/2026

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-26	TRIPPED ON OLR	RESET DONE	03:45:00	03:50:00	
2	CHP	CC-33 SCR-2	LT NOT WORKING PCRD DRUM SENSOR ACTED	RESET DONE	01:30:00	01:45:00	