



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/05/2026

Area: OHP

Equipment	Job
WOBR-3 ON co-29	bucket wheel motor failed, replace with spare one and trail run is taken, failed motor sent to ERS, Spare motor coupling is fixed and made ready.