



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 10/10/2026

Area: CHP

Equipment	Job
CC 28 TT	Cable rectification job done
CC 215/216 T/E	Extra pump provided and de watered
CCR Top	2 nos 200W LED fixtures replaced
CC 47,50,106,SCR 8	PPM was done
CC 51	MCCB module bus bar side single finger contacts replaced with double finger contacts
LC 19(CM 23)	Bus bar maintenance was done