



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 01/10/2026

Area: CHP

Equipment	Job
CC 18,55,56,57,58	PPM was done
CC 22	ZSS cable replaced and kept in ckt
LC 14 mast	Kept in auto mode,out going connectors replaced
SCR 2	Instrumentation sensors maintenance done
SCR 4	New modem configured and fixed
LC 2 cellar	Burnt submersible pump removed and new pump placed and de watering started
CC 47/48 gallery	6 nos 30W LED lamps provided
JH C 209	Sump pump trail run taken after mechanical job
CC 36,112,S1,SCR 8	PPM was done