



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 03/06/2026

Area: WT

Equipment	Job
CT-2	TRACK LIFTING DONE BY RAILWAY ... TRIAL TAKEN
OP-9	WINDOW COVERED WITH PLATE TO AVOID WATER ENTRY
MIS	VFD DRIVE CHECKING WITH ETL .. ONE DRIVE MADE READY
OP-8	VFD FIXED IN MOTOR 6 AND TESTED
OP-8	MOTOR -5 CHECKED FOUND OK