



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/06/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	21:40:00	21:50:00	
2	CHP	CC 51A	OLR ACTED	RESET	16:00:00	16:05:00	
3	CHP	CC 103 BRS	RESET PB LOOSE	TIGHTENED	19:35:00	19:45:00	
4	CHP	CC 44	OLR ACTED	RESET	19:20:00	19:25:00	
5	WT	OT3	D2 TRIPPED	RESET	19:30:00	19:40:00	
6	IOSA	IOSA	COMMUNICATION	POWER RECYCLED THEN OK	17:00:00	17:30:00	
7	IOSA	TBS ON OC 14A	CONTROL MCB TRIPPING FREQUENTLY	SUPPLY GIVEN FROM SEPARATE SOURCE	15:00:00	15:30:00	