



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/06/2026

Incharge(s): Nagendra Midde,Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	CC 131	OLR ACTED	RESET	02:00:00	02:05:00	
2	CHP	CC 52	FEEDING CONV OLR ACTED	RESET	03:15:00	03:20:00	
3	CHP	SCR 1 N CC 31	YARD INTERLOCK CAGE STUCK	MADE IT FREE	23:30:00	23:50:00	
4	CHP	CC 24	OLR ACTED	RESET	22:30:00	22:40:00	