



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 29/05/2026

Area: WT

Equipment	Job
OP-8	VFD DRIVE 6 AND 1 PROBLEM ... DRIVE 6 CHANGED AND KEPT IN CKT D... DRIVE -1 CHECKING UNDER PROCESS
CP-1 AND CP-3	MOTOR AND PANEL SIDE PPM DONE
OP-4	ROOF PAINTING DONE
OT-1	MOTOR AND PANEL SIDE PPM DONE