वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 13/11/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR acted	Reset	15:30:00	19:00:00	2 times
2	OHP	BRC on CO 31	Breaker tripped	Reset	18:50:00	19:10:00	
3	OHP	Co 26	OLR acted	Reset	20:40:00	21:40:00	2 times
4	OHP	WBR on co 29	Main Breaker tripped	Made it on	21:00:00	21:15:00	