RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 11/11/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	olr acted	reset	05:48:00	05:54:00	2 times
2	OHP	CO11	p/c not healthy,loop wire loose connection	tightened	22:35:00	22:50:00	
3	OHP	TBS on CO 21	LT not working,due to mech gear box problem	informed operation and mech	04:18:00	04:30:00	
4	CHP	cc 131	olr acted	reset	04:40:00	04:45:00	
5	CHP	vf 3	mpd tripped	reset	02:55:00	03:00:00	
6	CHP	CC 213 scr8	b/c not running in reclaiming mode	check found all ok,ccr side selection problem	00:30:00	00:45:00	
7	CHP	CC 106 scr3	b/c not running in reclaiming mode	check found all ok,ccr side selection problem	02:55:00	03:10:00	
8	CHP	CC 108	olr acted	reset	01:10:00	01:15:00	
9	CHP	CC 38 scr6	LT and slew not working,acb is in off	made on	04:50:00	05:00:00	
10	WT	OP4	no movement,acb tripped ,c7u clamp damaged @col no 27 and 28	acb made on,c and u clamp replaced at parking zone ... no delay rack taken in OP3...	02:00:00	02:50:00	trolley line to be checked