



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/06/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on co 7A	LT not working,PCRD OT acted	OT released	12:22:00	12:40:00	
2	OHP	co25	OLR acted	reset	07:10:00	07:20:00	3 times
3	CHP	CC 201	OLr acted	reset	07:15:00	07:20:00	
4	CHP	cc 37 scr7	luff not working,oil level low	informed to mechanical	06:45:00	06:50:00	
5	CHP	CC 125	MPD tripped	reset	11:10:00	11:15:00	