RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 25/10/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR acted	Reset	15:55:00	21:50:00	3 times
2	OHP	CO 25	OLR acted	Reset	19:10:00	20:20:00	2 times
3	OHP	CO 34	OLR acted	Reset	19:25:00	21:00:00	2 times
4	OHP	BRC on CO 32 Lt	M3 OLR acted (CRMP side)	Reset	15:40:00	15:50:00	
5	OHP	TBS on CO 22	ACB trip	Made it on	15:20:00	15:30:00	
6	OHP	VF 3	Mpcb Trip	Reset	20:00:00	20:10:00	
7	CHP	CC 212	C/S return core not connected properly	Tightened	15:15:00	15:30:00	
8	CHP	CC 15	OLR acted	Reset	15:30:00	15:40:00	
9	CHP	CC 54	OLR acted	Reset	17:10:00	17:40:00	
10	CHP	CC 131	OLR acted	Reset	17:00:00	17:05:00	