



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 04/09/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

| Sl No | Area | Equipment | Problem                                      | Action               | From     | To       | Remarks |
|-------|------|-----------|----------------------------------------------|----------------------|----------|----------|---------|
| 1     | OHP  | CO 25     | OLR ACTED                                    | reset                | 08:34:00 | 08:42:00 |         |
| 2     | OHP  | co 26     | OLR ACTED                                    | reset                | 10:25:00 | 10:35:00 | 2 times |
| 3     | OHP  | CC 52     | mpd acted                                    | reset                | 13:15:00 | 13:20:00 |         |
| 4     | OHP  | cc 36 s1  | slew not working,plc no power,mcb tripped    | made it on           | 06:30:00 | 06:40:00 |         |
| 5     | CHP  | cc 36     | cs acted,module no supply,phase wire in open | phase wire connected | 06:45:00 | 06:55:00 |         |