



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 10/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

| Sl No | Area | Equipment    | Problem                                | Action             | From     | To       | Remarks |
|-------|------|--------------|----------------------------------------|--------------------|----------|----------|---------|
| 1     | OHP  | co 16        | olr acted 3 times                      | reset              | 01:01:00 | 01:05:00 |         |
| 2     | OHP  | co 76R       | olr acted 2 times                      | reset              | 04:55:00 | 05:00:00 |         |
| 3     | OHP  | BRC on Co 32 | b/w 2 not running,guide roller problem | informed operation | 00:20:00 | 00:40:00 |         |
| 4     | CHP  | CC 52        | mpd tripped 2 times                    | reset              | 02:50:00 | 02:55:00 |         |
| 5     | CHP  | cc 125       | mpd tripped in olr                     | reset              | 00:00:00 | 00:05:00 | 3 times |
| 6     | CHP  | CC 38 scr 5  | LT not working,track jamming           | informed operation | 02:45:00 | 02:53:00 |         |