



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/09/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR on co 6a	LT not working,M6 trip	Reset	08:50:00	09:08:00	motor r-e,y-e,b-e IR value zero.cable removed
2	OHP	CC 34 S3	modem to PLC,communication not working	ethernet cable unplugged plugged	06:45:00	07:15:00	
3	OHP	co 58	olr acted	reset	07:20:00	07:30:00	
4	OHP	brc on co 28	lt not working,brake panel fuse blown	fuse replaced	08:00:00	08:20:00	
5	CHP	CC 131	motor tripped in OL	reset	09:45:00	09:50:00	