



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/06/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 16	OLR acted	reset	15:00:00	15:10:00	
2	OHP	CO 26	olr acted	reset	18:30:00	18:40:00	
3	OHP	WOBR on CO 29	LUff not working,OLR acted	reset	19:00:00	19:15:00	
4	OHP	BRC on CO 28	bc not running,b/w running,belt having no tension	mechanical problem	17:55:00	18:10:00	
5	OHP	co 25	olr acted	reset	19:40:00	19:50:00	
6	OHP	wobr on co 26	LT not working,wrong complaint	checked and found all ok	17:00:00	17:15:00	
7	CHP	cc 58	OLR acted	reset	21:00:00	21:05:00	
8	CHP	CCC 40 SCR7	B/C not running,30 degree slew limit acted	slew done than ok	14:35:00	14:40:00	
9	CHP	CC 43	olr acted	reset	19:00:00	19:05:00	
10	CHP	CC 40 SCR7	slew right not working,30 degree limit acted	limit released than ok	21:00:00	21:10:00	
11	WT	OT 3	D2 tripped on saturation fault	reset	16:30:00	16:35:00	