



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 21/05/2026

Area: CHP

Equipment	Job
CC 21/22 gallery	Lighting improved
JH C 3	Hoist panels maintenance was done
CHP	Spare motor details collected and noted
CM 18	Old PLC panels components removed
CM 18	Rooms cleaning done
R 1	B/W oil pump replaced and trail run was taken. MPCB replaced PLC and control desk maintenance was done
CC 43/44	CC 38 point Tunnel blower fan kept running
CC 47,50, 132	PPM was done
CC 53	Spare motor shifted up to bed
CC 52,CC 130	Chute vibrators cables laid and manual operation given