



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/07/2026

Shift: A

Incharge(s): Nagendra Midde, M Srinivas

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	Olr acted	Reset	07:35:00	07:45:00	
2	OHP	TBS on CO 7a	Breaker Tripped	Made it on	09:40:00	09:55:00	
3	CHP	CC 131	Olr acted	Reset	09:50:00	09:55:00	
4	CHP	CC 203	Olr acted	Reset	07:40:00	07:50:00	