



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/04/2026

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment       | Problem                                          | Action          | From                 | To                   | Remarks |
|-------|------|-----------------|--------------------------------------------------|-----------------|----------------------|----------------------|---------|
| 1     | OHP  | CO 26           | OLR ACTED                                        | RESET           | 00:50:00             | 04:20:00             | 3 TIMES |
| 2     | OHP  | TBS ON CO 5A LT | PCRD O/T ACTED                                   | RELEASED        | 02:15:00             | 02:25:00             |         |
| 3     | CHP  | CC 31           | OLR ACTED                                        | RESET           | 05:30:00             | 05:35:00             |         |
| 4     | CHP  | CC 28           | OLR ACTED                                        | RESET           | 05:45:00             | 05:50:00             |         |
| 5     | CHP  | CC 201          | OLR ACTED                                        | RESET           | 03:35:00<br>23:45:00 | 03:45:00<br>23:55:00 |         |
| 6     | CHP  | CC 107          | OLR ACTED                                        | RESET           | 01:05:00             | 05:25:00             | 3 TIMES |
| 7     | WT   | CT 1 NOT MOVING | EMERGENCY SWITCH CONTACT NOT CONTACTING PROPERLY | PROPERLY PLACED | 04:00:00             | 04:45:00             |         |
| 8     | WT   | C P 2           | BREAKER TRIP                                     | MADE IT ON      | 03:05:00             | 03:20:00             |         |