



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/05/2026

Shift: A

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 16	OLR ACTED	RESET	08:20:00 12:55:00	08:30:00 13:00:00	
2	OHP	BRC ON CO 8A CT	EMERGENCY PB NOT RELEASED	RELEASED	10:50:00	11:00:00	
3	OHP	CO 33 A	ZSS PROBE DAMAGED	BYPASSED	12:40:00	12:50:00	
4	OHP	CO 21	MECH BRS PROBE MALFUNCTIONING	BYPASSED	06:50:00	07:30:00	
5	CHP	CC 21 CD	MPCB TRIP	MADE IT ON	06:45:00	06:55:00	
6	CHP	SCR 5 ON CC 38	OUT PUT RELAYS 24V -VE IN MCB POLE DAMAGED	REPLACED	07:55:00	08:20:00	
7	CHP	SCR1 ON CC 31 B/C	COMMUNICATION PROBLEM	LT DONE	09:40:00	09:50:00	
8	CHP	SCR 4 ON CC 32	LT PCRD CABLE ZIG ZAG	AFTER MECH CLEARANCE WINDING DONE	10:40:00	11:20:00	
9	CHP	SCR 2 ON CC 33	LUFF OIL TEMP HIGH	BYPASSED AND REMOVED AFTER SOME TIME	12:30:00	12:40:00	