



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/05/2026

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-16	TRIPPED ON OLR	RESET DONE	03:15:00 03:50:00	03:25:00 04:00:00	
2	OHP	CO-32 BRC	PUMP STOPPING ON CHARGE PRESSURE	MOTOR AND PUMP NOT ENGAGING .. BOTH SIDE COUPLING AND SPIDER DAMAGED . NEW COUPLING FIXED IN MOTOR MECHANICAL JOB GOING ON	23:00:00	06:00:00	
3	CHP	CC-104 SCR-6	BC NOT RUNNING ... CJD ACTED DUE TO MOISTURE	CJD BYPASSED	04:50:00	05:05:00	
4	CHP	LC-19	INCOMER -1 TRIPPED	RESET	02:00:00	02:15:00	
5	CHP	CC-131	MPD TRIPPED 2 TIMES	RESET DONE	02:50:00	05:00:00	
6	CHP	CC-130	TIS TRIPPED	RESET DONE	00:30:00	00:40:00	