



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 16	olr acted 3 times	reset	01:01:00	01:05:00	
2	OHP	co 76R	olr acted 2 times	reset	04:55:00	05:00:00	
3	OHP	BRC on Co 32	b/w 2 not running,guide roller problem	informed operation	00:20:00	00:40:00	
4	CHP	CC 52	mpd tripped 2 times	reset	02:50:00	02:55:00	
5	CHP	cc 125	mpd tripped in olr	reset	00:00:00	00:05:00	3 times
6	CHP	CC 38 scr 5	LT not working,track jamming	informed operation	02:45:00	02:53:00	