RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 14/10/2026

Area: CHP

Equipment	Job
CC 8	Faulty MCCB replaced with Schneider 630A MCCB and trail run taken. 2nos jumper lugs replaced
SCR 3	Instrumentation sensors maintenance was done
CC 49/50 gallary	6 nos 30W LED lamps replaced and improved lighting
CC 47/48	Tunnel area 4 nos 30W LED lamps replaced
SCR 8	LT panel control supply MCB replaced
CC 107,108,125	PPM was done
CM 9,CM 19,CM 27	Bus bar maintenance was done