



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/06/2026

Area: WT

Equipment	Job
CP-2	TROLLEY LINE CHECKED AND PROBLEM RECTIFIED NEAR COL. NO 43
MIS	ONE VFD DRIVE MADE READY FOR OP-8 AND VECON DRIVE TESTED FOR REPLACEMENT OF D-2 IN OT-3
EOT COAL	AUX HOIST MOTOR CHECKED ... CABLE REPLACED .. CONTROL PROBLEM RECTIFIED AND TESTED