



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 04/05/2026

Area: OHP

Equipment	Job
PETE 400 KVA spare HT transformer	base found oil leak is there , planned to ERS for repair works.
vf-2a spare motor	revisioning is under process.
co-15 pullchord	circuit checked, and restored in circuit.
wobr-3 on repair bay, boom conveyor	failed motor coupling removed, fixed to spare one and alignment is done.