



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/07/2026

Incharge(s): M Kailash

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr 3 on co 25	LT NOT TAKING PLACE/PCRD LIMIT OPERATING LIVER BROKEN	LIMIT LIVER WELDING DONE.	22:45:00	23:05:00	NO DELAY
2	OHP	WOBR 1 ON CO 26	LUFFING NOT TAKING PLACE/PUMP OLR ACTED	RESET DONE	00:15:00	00:30:00	
3	OHP	CO 26	TRIPPED ON OLR	RESET DONE	01:00:00	01:05:00	
4	OHP	TBS 1 ON CO 22	LT NOT TAKING PLACE/MPCB S OFF CONDITION	MPCB S MADE ON	01:45:00	01:55:00	
5	OHP	CO 29	TRIPPED ON OLR	RESET DONE	03:55:00	04:05:00	
6	OHP	TT 2 ON CO 15	CHUTE VIBRATOR NOT WORKING/ROTOR STUCKUP	BEARING S PROBLEM	02:05:00	02:55:00	MOTOR TO BE REPLACED
7	CHP	CC 215	TRIPPED ON OLR	RESET DONE	00:30:00 05:10:00	00:40:00 05:20:00	
8	WT	CO 3	TRIPPED ON OLR	RESET DONE	02:30:00	02:40:00	