वी.एस.पी
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 10/11/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 1 | OHP | Co 26 | olr acted | reset | 03:00:00 | 03:15:00 | |
| 2 | OHP | VF 10 A | OLR acted | reset | 23:10:00 | 23:15:00 | |
| 3 | CHP | CC 112 S3 | b/c not running,mpd acted | reset | 22:20:00 | 22:30:00 | |
| 4 | CHP | CC 112 s3 | LT reverse not working,pcrd OT acted | released | 01:20:00 | 01:30:00 | |
| 5 | CHP | CC 32 scr5 | LT not working,OT acted | OT released | 02:50:00 | 03:05:00 | |
| 6 | CHP | cc 131 | motor tripped in olr | reset | 05:10:00 | 05:15:00 | |
| 7 | WT | OP2 | no movement,D1 olr acted | reset | 03:30:00 | 03:45:00 | |