



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/10/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 50	OLR acted	Reset	16:00:00	16:15:00	
2	OHP	WBR on CO 29	Luff not working due to Jamming	After clearing then ok	16:30:00	16:45:00	
3	OHP	WBR on co 29 LT	M3 OLR acted	Reset	20:25:00	20:40:00	
4	OHP	CO 12 CD	OLR acted	Reset	21:15:00	21:25:00	
5	CHP	CC 131	OLR acted	Reset	20:45:00	20:50:00	