



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/05/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 22 LT	SELECTOR SWITCH IN LOCAL	REMOTE	14:30:00	14:50:00	
2	OHP	BRC ON CO 28 B/C	EMERGENCY STOP ACTED	RELEASED	18:25:00	18:40:00	
3	OHP	BRC ON CO 28 B/C	OLR ACTED DUE TO JAMMING	RESET	19:20:00	19:30:00	
4	CHP	CC 33	OLR ACTED	RESET	21:15:00	21:20:00	
5	CHP	SCR 6 ON CC 104	LT M2 TRIP	MADE IT ON	19:55:00	20:05:00	