वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 12/10/2026

Area: WT

Equipment	Job
U 7 -9 and U 19 -21	Power block arranged for painting
SCO1A	Carriage drive power cable one phase found cut, re jointed
OP 8	Trolly line insulators replaced 20 nos (93 to 102)
OP 10	Trolly line inspection done
CP 1 and 2	Trolly line inspection done