



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/06/2026

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	OLR ACTED	RESET DONE	19:45:00	19:55:00	
2	CHP	CC-51	MPD TRIP	RESET DONE	15:45:00	15:50:00	
3	CHP	CC-54	OLR ACTED (2TIMES)	RESET DONE	15:55:00	16:00:00	
4	CHP	CC-43	REPORTED STOPPING ON ZSS FOUND ZSS PROBE DAMAGE	ZSS PROBE REPLACED WITH NEW ONE THAN OK	21:15:00	21:45:00	
5	CHP	CC-107	OLR ACTED (2TIMES)	RESET DONE	17:00:00 20:25:00	17:05:00 20:30:00	
6	WT	CO-3 (B) DRIVE	OLR ACTED	RESET DONE	16:50:00	16:55:00	