



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 18/07/2026

Area: WT

Equipment	Job
OT 2	stream bypass selector switch replaced
OT 5	Angles welding and Device fixed for tippler initial indication
LC 10A	Lighting timer provided to peripheral area lighting
MIS	Track focusing lights 3 nos provided @ walkway bridge towards OT complex