



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 19/06/2026

Area: CHP

Equipment	Job
CC 52,53	PPM was done
CC 51 tunnel	6 nos LED fixtures replaced. Now all installed lights inside the tunnel are glowing
CC 28/29 Gallery	4 nos bay lamps replaced and ckt problem rectified
CC 12/13 Gallery	10 nos LED fixtures replaced and defective fixtures removed
SCR 8	HT cable twists removed
CC 39,40,S2,SCR 6	PPM was done
SCR 10	Shifted from CC 213 to CC 106