



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/06/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

| Sl No | Area | Equipment    | Problem                        | Action                 | From     | To       | Remarks |
|-------|------|--------------|--------------------------------|------------------------|----------|----------|---------|
| 1     | OHP  | TBS on co 7A | LT not working,PCRD OT acted   | OT released            | 12:22:00 | 12:40:00 |         |
| 2     | OHP  | co25         | OLR acted                      | reset                  | 07:10:00 | 07:20:00 | 3 times |
| 3     | CHP  | CC 201       | OLr acted                      | reset                  | 07:15:00 | 07:20:00 |         |
| 4     | CHP  | cc 37 scr7   | luff not working,oil level low | informed to mechanical | 06:45:00 | 06:50:00 |         |
| 5     | CHP  | CC 125       | MPD tripped                    | reset                  | 11:10:00 | 11:15:00 |         |