वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 28/10/2026

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs on co 5a	NO RUNNING/CONTROL T/F MCB 415V GOT SHORT FOR T2	MCB OUT GOING DIS CONNECTED AND T/F 1 POWER MADE ON TESTED OK	08:05:00	08:30:00	MEAN WHILE GATE CHANGING
2	OHP	CO 5A	BRS ACTED	BYPASSED DUE TO RAIN	08:20:00	08:45:00	
3	OHP	CO 35	BRS ACTED/GLASS FUSE BLOWN	FUSE REPLACED	08:40:00	09:00:00	
4	OHP	CO 26	TRIPPED ON OLR	RESET DONE	08:00:00	08:10:00	
5	OHP	RCO 6A	ZSS ACTED/PROBE GOT DIRECTED	REPLACED AND TESTED OK	10:25:00	10:50:00	
6	OHP	CO 11A,CO 20,5A	REPORTED RED/HIGH SPEED RELAY TRIPPED	RESET DONE	10:35:00	10:55:00	
7	OHP	CO 38A	REPORTED RED /CONTROL MCB TRIP	MCB MADE ON	11:20:00	11:40:00	
8	OHP	BRC ON CO 8A	NO DRIVES RUNNING/PLC POWER OFF	PLC POWER MADE ON	12:30:00	12:45:00	
9	OHP	TT 4 ON CO 22	NO POWER/CONTROL SUPPLY FUSE BLOWN	FUSE REPLACED	13:05:00	13:25:00	
10	OHP	TBS ON CO 7A	LT NOT TAKING PLACE/M1 TRIPEED ON OLR DUE TO TRACKJAMMING	RESET AND INFORM TO OPERATION	13:00:00	13:10:00	
11	OHP	BRC ON CO 32	BC NOT RUNNING/EMERGENCY STOP PB OPERATED AT CABIN	PB RELEASED	12:30:00	12:45:00	
12	OHP	CO 25	TRIPPED ON OLR	RESET DONE	09:05:00 09:45:00	09:20:00 09:55:00	
13	OHP	WOBR ON CO 29	NO DRIVES RUNNING/CONTROL OFF CONDION	MADE ON	06:55:00	07:15:00	

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 28/10/2026

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	OHP	WOBR ON CO 29	LT NOT TAKING PLACE/BRAKES TIGHT	INFORM TO MECH.	06:55:00	07:15:00	
15	OHP	WOBR ON CO 29	LT NOT TAKING PLACE/DRIVE TRIPPED ON OLR	RESET DONE	12:05:00	12:25:00	
16	OHP	SCR 2 ONCC 32	LT NOT TAKING PLACE/PCRD TENSION ACTED	TENSION RELEASED	09:45:00	09:55:00	
17	CHP	SCR 6 ON CC38	END LIMIT BYPASS REQUEST FROM OPERATION	BYPASSED	09:50:00	10:00:00	
18	CHP	SCR ON CC 31	LT NOT TAKING PLACE/DRIVE TRIPPED	RESET DONE	10:15:00	10:30:00	
19	CHP	CC 112	REPORTED RED/MCB TRIPPED	MADE ON	11:45:00	11:55:00	
20	CHP	SCR 7 ON CC40	LUFFING NOT TAKING PLACE/FILTER CLOCOGG PROBLEM	INFORM TO OPERATION	11:25:00	11:40:00	
21	CHP	SCR 3 ON CC37	BC NOT RUNNING/OLR ACTED	RESET DONE	11:45:00	11:50:00	
22	CHP	SCR 1 ON CC31	BC STOPPING WHEN START BW	CHECKING IS GOING ON	13:30:00	14:00:00	
23	WT	CO 2 B/D	TRIPPED ON OLR	RESET DONE	08:50:00	08:55:00	
24	WT	CO 3 B/D	TRIPPED ON OLR	RESET DONE	09:45:00	09:50:00	
25	WT	OT 1	DRIVE TRIPPED ON OVER CURRENT	RESET DONE	13:15:00	13:20:00	