



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/10/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 19	zss acted,probe problem	probe replaced	00:20:00	00:30:00	
2	OHP	co 25	olr acted	reset	00:55:00	01:00:00	3 times
3	OHP	co 47	zss acted,checked found all ok,module doubt	module replaced	00:50:00	01:30:00	
4	OHP	co 36	olr acted	reset	02:50:00	02:55:00	
5	OHP	vs 2	olr acted	reset	05:22:00	05:30:00	
6	OHP	co 27 A	OLR acted	reset	23:00:00	23:15:00	
7	CHP	CC 131	motor tripped	reset	01:35:00	01:40:00	
8	CHP	CC 29	ZSS acted,material stucked in ZSS cage	cage made free	23:10:00	23:20:00	
9	CHP	CC 203	olr acted	reset	23:35:00	23:40:00	
10	WT	OP3	no power@ col no 86,acb tripped in LC	made it on	01:50:00	02:10:00	
11	IOSA	FLS woblr	LT not working,OT acted	released	01:50:00	02:05:00	